

South Central Railway

दक्षिण मध्य रेलवे



प्रधान कार्यालय / Headquarters Office,

विद्युत शाखा / Electrical Branch,

रेल निलयम् / Rail Nilayam,

सिकंदराबाद / Secunderabad-500 071.

No. E.220/Tr.D/Insulators/Vol.IX.

Date: 16.03.2015.

Director General (TI)
RDSO, Manaknagar
Lucknow - 226 011.

Sub: Performance feedback of 25 KV Solid Core porcelain Post, Sectioning, Operating Rod & 9-tonne Insulator of M/s Saravana Global Energy Ltd (M/s SGEL).

Ref: RDSO's letter no: TI/OHE/INS/SGEL/13 dt; 17.12.2014

As desired by the RDSO vide above reference , the Performance of 25 KV solid core post, Sectioning, Rod & 9-Tonne insulators of M/s Saravana Global Energy Ltd is furnished for kind information please.

Sl no	Division	Type of insulators	Batch No	Total no of insulators	Month & Yr of commissioning	Failure if any
1	Secunderabad	9-Tonne	2000	74	July-12	NIL
2			2010	75	Jun-13	
3			2011	700	Nov-14	
4			2012	15	Dec-14	
5		Operating	2009	24	July-12	
6			2011	14	Jun-13	
7			2012	26	July-12	
8		Pedestal	2009	60	July-12	
9			2010	70	Jun-13	
10			2011	6	Jun-13	
11			2012	80	Nov-14	
12		Section	2009	24	Jul-12	
13			2010	35	Jun-13	
14			2011	8	Jun-13	
15			2012	12	Jun-13	
16	Vijayawada	Operating	2011	42	Dec-13	
17			2009	11	Oct-11	
18		Pedestal	2011	84	Dec-13	
19			2009	22	Oct-11	
20			Section	2011	15	Dec-13
21	2009	12		Oct-11		
22	Hyderabad	9-Tonne	2009	59	Jan-10	
23		Operating	2009	13	Jun-10	
24		Pedestal	2009	42	Jun-10	
25		Section	2009	7	Jun-10	
Total				1530		

(Signature)
 16/3/15
(B.V. RAMANA KUMAR)
 DY.CEE/TRD/HQ
 for Chief Electrical Engineer