

Southern Railway



Headquarters office,
Electrical Branch,
Chennai - 600 003.
Date:-20.02.2014

No: 220/3/1/Insulator.

Executive Director/Traction Installations.
Research Designs and Standards Organisation,
Manak Nagar, Lucknow.

(kind attn.: Shri.V.K.Upadhyaya,(Director-TI/OHE-E)

Sub:-Performance feedback of 25kV Solid core post, Sectioning, Operating Rod & 9-tonne Insulator of M/s Saravana Global Energy Ltd. (M/s SGEL)-Reg.

Ref:-Your office letter No. TI/OHE/INS/SGEL/13 Dated:- 28.10.13

With reference to your letter cited above, performance feedback on M/s SGEL make porcelain insulators erected in the electrified territory of Southern Railway is furnished in RDSO's format below.

S.. N.	Type of insulator	Batch No.	Total No. of insulators	Month & year of commissioning	Failure if Any	Division
1	Sectioning insulator	02/2010	06	2010	Nil	Chennai
2.	Operating Rod insulator	02/2010	06	2010	Nil	

B.V. Chandra Shekar 20/2/13

(B.V.Chandra Shekar)
CEDE

For Chief Electrical Engineer

8/20/12

o/c
8/20/12